

All COR ISO Recommendations

Latent Condition, Seismic and ISS

Friday, October 12, 2012 12:50:08 PM

Type	Rec #	ABU	Unit	Year (I/R)	LC or ISS Question #	LC Question ISS Question Seismic Area	Observation	Recommendation	Resolution	Due Date	Assigned To	Status
Latent Condition	273	Isomax	SDA ROSE	2003	5-6	Are communications systems susceptible to electromagnetic interference during any operating mode of the plant?	X-rays interfere with radioactive alarms- operators informed of phenominia	Communicate & train operations on phenomena of X-Ray interference with radioactive detectors	Operations has been notified that X-Ray may interfere with radioactive detectors. The communication requires operations to be aware of when X-Ray Crews are in the work area, and the appropriate process control changes necessary to prevent interference	12/31/2004	Miller, Mark A.	Completed